



- 1) APPROVED ASSEMBLIES ARE REQUIRED TO HAVE RESILIENT SEATED SHUT-OFF VALVES AND TEST COCKS AS INTEGRAL PARTS OF THE ASSEMBLIES OTHERWISE THE APPROVAL IS VOIDED.
- 2) ASSEMBLY MUST BE ACCESSIBLE FOR TESTING AND MAINTENANCE.
- 3) PROTECTION FROM FREEZE DAMAGE MAY BE REQUIRED IN EXPOSED AREAS.
- 4) NO CONNECTIONS OR TEES WILL BE ALLOWED BETWEEN METER AND ASSEMBLY.
- 5) INSTALLATION AND OPERATION MUST COMPLY WITH STANDARDS SET FORTH BY A.W.W.A. AND ALL FEDERAL, STATE, AND LOCAL LAWS, RULES, REGULATIONS, ORDERS, CODES, AND ORDINANCES.
- 6) THE D.C.V. ASSEMBLY SHALL BE INSTALLED AS CLOSE TO THE METER AS PRACTICAL. ANY DEVIATION FROM THIS METHOD MUST BE APPROVED BY CLWSC PRIOR TO INSTALLATION.
- 7) IN NO CASE SHALL THIS ASSEMBLY BE INSTALLED BELOW GRADE WITHIN A VAULT OR IN A PIT.

GENERAL NOTES:
 (1) FOR ADDITIONAL INFORMATION, SEE CANYON LAKE WATER SERVICE COMPANY'S STANDARD SPECIFICATIONS.

BY	REVISION	DATE	CK	AP	OPS

CLWSC
 CANYON LAKE
 WATER SERVICE COMPANY
 1399 Sattler Road
 Canyon Lake, Texas 78133
 (830) 964-3854

**APPROVED
 DOUBLE CHECK VALVE
 ASSEMBLY INSTALLATION**

BY: PJ / JW / MH	OPERATIONS / DATE
DATE: 02-11-09	ENGINEERING / DATE
SCALE: NONE	DIRECTOR OF ENGINEERING / DATE

REF. NOS. D-5-651
DWG. NO. BK-DCV
SHEET: 1 OF 1