



- NOTES:
1. SERVICE SADDLES SHALL BE WRAPPED COMPLETELY WITH 8 MIL. POLYETHYLENE FILM.
  2. PIPING AND TUBING SHALL BE BEDDED IN GRANULAR MATERIALS AS REQUIRED IN THE SPECIFICATIONS.
  3. METER SUPPLIED BY CLWSC (PAID FOR BY CUSTOMER),

SERVICE SADDLE REQUIRED ON PLASTIC PIPE AND IRON PIPE UNDER 8" DIAMETER SEE STANDARD SPECIFICATIONS FOR FURTHER REQUIREMENTS.

GENERAL NOTES:  
 (1) FOR ADDITIONAL INFORMATION, SEE CANYON LAKE WATER SERVICE COMPANY'S STANDARD SPECIFICATIONS.

MH	UPDATE DRAWING	06-02-10			
MH	UPDATE DRAWING	04-25-10			
BY	REVISION	DATE	CK	AP	OPS



CANYON LAKE  
 WATER SERVICE COMPANY  
 1399 Sattler Road  
 Canyon Lake, Texas 78133  
 (830) 964-3854

**1" SERVICE**

BY: JW / M.HOMER	OPERATIONS / DATE
DATE: 02-11-09	
CK:	ENGINEERING / DATE
SCALE: NONE	DIRECTOR OF ENGINEERING / DATE

REF. NOS.	DWG. NO.
	SER-1
	SHEET: 1 OF 1